


# EDGE TROFFER REMOTE Installation Guide




NOTICE:

- For correct installation, a qualified electrician should install this product.
- Before installation of any luminaire onto an electrical junction box, be sure to disconnect power.
- This luminaire must be wired and grounded in accordance with the National Electrical Code, local codes, and ordinances.
- Wire supply connections must be made with UL approved connectors.
- Confirm that luminaire and supply voltage are the same.
- This installation instruction is a general reference for installation and maintenance. Refer to your order details as fixture component or hardware may vary.

OVERALL FRONT AND SIDE DIMENSIONS:



OVERALL FOOTPRINT:



INSTRUCTIONS:

1. Disconnect electrical lighting circuit (at breaker panel). Please check all local codes before install.
2. Edge recessed remote driver troffer is composed of a low profile sheet metal housing and frosted lens. The troffer is suitable for standard commercial 15/16" inverted T-bar grid ceilings. Class 2 power supply is provided separately.
3. Recessed troffer to be wired on site with remote driver unit. GC to open access knockout panel to access internal LED board wiring. GC is responsible for supplying on-site cabling or conduit from the fixture to remote driver units. Please check all local codes before install. Wiring fixture to source DC wiring, using UL listed wire connectors: connect the luminarie positive (red) wire to the power supply positive output, connect the luminarie negative (black) to the power supply negative output. Always follow factory labels.
4. Inspect wire connections.
5. Attached troffer to ceiling structure per local code. GC is responsible to provide required mounting hardware, and safety cables, per ceiling conditions. Follow grid ceiling specifications for supporting weights and lighting placement.
6. Enjoy your new luminarie!

CAUTION:

- FIXTURE WEIGHT APPROXIMATELY 6LBS 4F LONG FIXTURE &12 LBS 8F LONG FIXTURE
- CONTRACTOR REQUIRED TO PROVIDE APPROPRIATE STRUCTURAL SUPPORT (JUNCTION BOXES, CEILING TILE BRIDGE, FRAMING, ETC) FOR FIXTURE TO MEET LOCAL CODE REQUIREMENTS.
- AVOID INSTALLING THIS FIXTURE NEAR AREAS OF HIGH AIR MOVEMENT (HVAC VENTS, DOORWAY, WINDOWS) TO MINIMIZE FIXTURE SWAY.
- DO NOT FEED EXCESS AIRCRAFT CABLE INTO FIXTURE OR JUNCTION BOX WHERE ELECTRICAL WIRES ARE LOCATED
- EXERCISE SPECIAL CARE AND SAFETY WHILE INSTALLING AND SERVICING LUMINAIRE.
- USE OF SOFT GLOVES AND PADDED MATERIALS ARE RECOMMENDED DURING HANDLING TO AVOID MARRING THE FINISH.
- COMPONENTS MAY BE CLEANED WITH SOFT DAMP OR DRY CLOTH.

EXPLODED VIEW  
TROFFER COMPONENTS

